



GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE



Ack. No.: 123700002018
NOC: 0005564/OCCU/Medchal/2018



NOC TYPE: OCCUPANCY *

Valid Upto: 21-12-2023

Applicant Details: MD Tajuddin-9700094835/Sy.No. 472, 474, 476, 486, 487, 493 & 494, Bal Reddy Nagar, Dammaiguda, Keesara Mandal, Medchal District.

Building for which NOC issued: Oxford School-Sy.No. 472, 474, 476, 486, 487, 493 & 494, Bal Reddy Nagar, Dammaiguda, Keesara Mandal, Medchal District.

Concessions in Setbacks Given in Lieu of Land Surrendered in Road Widening:	No.			
Plot Area (Sq. Mtrs)	5172.00	Height (Metres):16.60		
Open Spaces (Metres):	North (F): 7.00	South: 6.00	East: 7.00	West: 7.00
No. of Floors:0Cellar,0Stilts,1Ground, 4Floor,0Terrace	Occupancy Type:		EDUCATIONAL senior secondary B-1 Schools up to level	
Total Built-up Area (Sq.Mtrs)	7736.7	Staircases:	No. of Staircases Required/Proposed:	2
Fees Paid(Rs.):	77367.00		Aggregate Width Required/Proposed (Metres):	5.00

Minimum Fire Fighting Installations Provided as per Table 7, Part-IV of NBC, 2016:

Fire Extinguisher:	30	First Aid Hose Reel:	5	Wet Riser:	0
Down Corner:	1	Yard Hydrant:	0	Automatic Sprinkler System:	0
Manually Operated Electronic Fire Alarm Systems:	0	Terrace Tank (Liters):	10000		
Automatic Detection and Alarm System:	0	Underground Static Water Storage Tank (Liters):	0		

Pump Near Underground Static Water Storage Tank (Fire Pump) with Minimum Pressure of 3.5 kg/cm² at Terrace Level

Type	Quantity	(Capacity in Litres/min)
Electrical	0	0
Diesel	0	0
Jockey	0	0

Fire Pump at the Terrace Tank Level with Minimum Pressure of 2.0 kg/cm²

(Capacity in Litres/min)
900

THIS IS COMPUTER GENERATED DOCUMENT AND DO NOT REQUIRE ANY STAMP OR SIGNATURE*
* For details and conditions of No Objection Certificate For Occupancy, refer overleaf

[Signature]
Manager
Oxford School
Dammaiguda

[Signature]
Principal
Oxford School
Dammaiguda

Scanned by CamScanner

Scanned by CamScanner




GOVERNMENT OF TELANGANA
STATE DISASTER RESPONSE FIRE SERVICES DEPARTMENT
NO OBJECTION CERTIFICATE




The No Objection Certificate for Occupancy is issued subject to following conditions:

- The applicant should follow the Serial No.1, 4 of Form No.18 [See Rule 15(1) (f)] of Telangana Fire and Emergency Operations and Levy of Fee Rules, 2006.
- In pursuance of the orders of the Hon'ble High Court mentioned above at Sl.No.18 and on the basis of the recommendations of the building inspection committee, this No Objection Certificate for Occupancy is issued.
- Any person violating the conditions of a No Objection Certificate shall be liable to be proceeded against under the provisions of Fire Service Act, 1999.
- The Owner/Occupier may please note that, the department will conduct surprise inspections to verify the satisfactory working condition of the fire safety systems. During the inspection, if any violation of No Objection Certificate for Occupancy conditions/non-functioning of fire safety systems is noticed, prosecution will be launched on the Owner/Occupier as per the provisions of Fire Service Act, 1999.
- It is the responsibility of the builder /management to apply for Renewal of No Objection Certificate for Occupancy duly remitting the user charges as per G.O.Ms.No.71, (Home Prisons-A) Dep., dated:01-04-2010, two months before expiry of this No Objection Certificate.
- The floor wise built-up areas of the building are as follows:

Floor Type	BuildUpArea
Ground	1547.34
1st Floor	1547.34
2nd Floor	1547.34
3rd Floor	1547.34
4th Floor	1547.34
Total	7736.7


Manager
Oxford School
Dammalguda


Principal
Oxford School
Dammalguda

Scanned by CamScanner

Scanned by CamScanner